

CITY OF CHOWCHILLA CALIFORNIA



**ADDENDUM NO. 2
City of Chowchilla
Roof Replacement: Civic Center Plaza**

All bidders are hereby notified of the following modification to the contract documents, construction specifications and construction plans. This modification is to become a part of said contract documents, construction specifications and construction plans.

Acknowledge receipt of this Addendum by signing below. Failure to acknowledge may result in the proposal being rejected as not responsive.

I acknowledge that I have received and reviewed Addendum No. 2, and will include its provisions in the bid.

By (Print Name and Title)

Signature

Date

Company

This Addendum shall supersede all previously issued specifications and drawings wherein it contradicts same. All other conditions remain unchanged. The following changes, modifications, corrections, clarifications, and/or additions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all of the requirements thereof as though originally specified and/or shown.

City of Chowchilla
130 S. Second St, Chowchilla, Ca. 93610
Tel: 559-665-8615 Fax: 559-665-8629

ADDENDUM #2

TITLE: ROOF REPLACEMENT: CIVIC CENTER PLAZA
ADDENDUM ISSUE DATE: August 31, 2017
CLOSING DATE & TIME: ON September 14, 2017 at 2:00 PM


Information for Proponents

The following information is provided in answer to questions raised by Potential Proponents on August 31, 2017.

This addendum #1 contains 3 page in total.

Question #1: Which type of roof material will be required to be used TPO or PVC?

Answer: **Please replace page 7 of the RFP, Section 2.2 Number 7 with this table to be submitted with bid package. Clarification a TPO material will be the required material.**

Approved By: 

Jason Rogers, Public Works Director

Dated: 8/31/17

All Addenda will become a part of the Contract Documents.

BID PRICE**Base Bid**

<u>Item No.</u>	<u>Description</u>	<u>Quantity</u>	<u>Units</u>	<u>Unit Price</u>	<u>Extension</u>
1.	20-year Sika Plan/Sarnafil or comparable material roof warranty	1	L.S.	\$ _____	\$ _____
2.	20-year Sika Plan/Sarnafil or comparable material TPO 60 mil TPO vinyl membrane	1	L.S.	\$ _____	\$ _____
3.	20-year TPO roofing material	1	EACH	\$ _____	\$ _____

Total Base Bid: \$ _____

Total Base Bid in Words: _____

Bid Alternative #1

<u>Item No.</u>	<u>Description</u>	<u>Quantity</u>	<u>Units</u>	<u>Unit Price</u>	<u>Extension</u>
1.	15-year Sika Plan/Sarnafil or comparable material roof warranty	1	L.S.	\$ _____	\$ _____
2.	15-year Sika Plan /Sarnafil or comparable material TPO 60 mil TPO vinyl membrane	1	L.S.	\$ _____	\$ _____
3.	15-year TPO roofing material	1	EACH	\$ _____	\$ _____

Total Bid Alternative #1: \$ _____

Total Bid Alternative #1 in words: _____

Bid Alternative #2

<u>Item No.</u>	<u>Description</u>	<u>Quantity</u>	<u>Units</u>	<u>Unit Price</u>	<u>Extension</u>
1.	10-year Sika Plan /Sarnafil or comparable material roof warranty	1	L.S.	\$ _____	\$ _____
2.	10-year Sika Plan /Sarnafil or comparable material TPO 60 mil TPO vinyl membrane	1	L.S.	\$ _____	\$ _____
3.	10-year TPO roofing material	1	EACH	\$ _____	\$ _____

Total Bid Alternative #2: \$ _____

Total Bid Alternative #2 in words: _____